

Laboratory Report
Report ID: 102110



Sierra
Environmental
Monitoring, Inc.

SPB Utility Services

430 Stoker Avenue, Suite 207
Reno, NV 89503

Date: 11/19/2009
Client: SPB-491
Taken by: B. Pace
PO #:

Analysis Report

Sample ID: S200911-0373 Customer Sample ID: Sand Creek #0406 - Well 1 after treatment Date Sampled: 11/5/2009 Time Sampled: 11:00 AM Date Received: 11/5/2009

Parameter	Method	Result	Units	MCL	Analyst	Date Analyzed	Data Flag
Arsenic - ICP-MS	EPA 200.8	<0.001	mg/L	0.010 mg/L	Kobza	11/17/2009	
Manganese - ICP-MS	EPA 200.8	<0.003	mg/L	0.05/0.10 mg/L	Li	11/13/2009	B

SAMPLE WATER AS TESTED ~~DID~~ DID NOT MEET DRINKING WATER STANDARDS.

Data Flag Legend:

B - Element or compound also found in associated Method Blank.

RECEIVED
NOV 20 2009
BY: _____